

CERTIFICATE

Certificate holder**Vaillant GmbH
Berghauser Str. 40
42859 Remscheid****Production facility**Gelsenkirchen
Nantes**Product**

Solar collectors

Type, Model

VFK 135/2 D, VFK 135/2 VD

Testing basisDIN EN 12975-1:2011-01
DIN EN 12975-2:2006-06
Specific CEN KEYMARK Scheme Rules for Solar Thermal Products version 19.00
(2012-10)**Mark of conformity****Registration No.**

011-7S477 F

Valid until

2018-05-31

Right of use

This certificate entitles the holder to use the mark of conformity shown above in conjunction with the specified registration number.

See annex for further information.

ANNEX

Page 1 of 1

Certificate	011-7S477 F dated 2013-06-20
Technical Data	See data sheet, part of the test report of 2013-05-29 Note(s): - The freeze resistance test according to DIN EN 12975-2, clause 5.8 was not necessary. According to the manufacturer's declaration, the certified solar collectors may be used in frost exposed areas only in combination with appropriate frost protection mixtures. - The optional impact resistance test according to DIN EN 12975-2, clause 5.10 was not carried out.
Testing laboratory/ Inspection body	TÜV Rheinland Energie und Umwelt GmbH Test Centre for Energy Appliances Am Grauen Stein 51105 Köln
Test report(s)	No. 21221150_EN_P_135-2D, No. 21221150_EN_R_135-2D, No. 21221150_EN_P_135-2VD, No. 21221150_EN_R_135-2VD dated 2013-05-29



50m